

Detailed Asset List

COFFEE ON CUE
19 Hall St
YARRAVILLE 3013



Client:COFFEE ON CUE 1/26								
Site: COFFEE ON CUE								
Location: JAN 2026								
Asset ID	Description	Make	Model	Serial No	Last Test	Next Test	Last Visual	Next Visual
JC00149050	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149051	MILK FRIDGE				20/01/2026	20/01/2027	20/01/2026	
JC00149052	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149053	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149054	MILK FRIDGE				20/01/2026	20/01/2027	20/01/2026	
JC00149055	MILK FRIDGE				20/01/2026	20/01/2027	20/01/2026	
JC00149056	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149057	MILK FRIDGE				20/01/2026	20/01/2027	20/01/2026	
JC00149058	MILK FRIDGE				20/01/2026	20/01/2027	20/01/2026	
JC00149059	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149060	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149061	COFFEE GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149062	COFFEE GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149063	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149064	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149065	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149066	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149067	COFFEE GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149068	RCD POWER BOARD	HPM 30MA			20/01/2026	20/01/2027	20/01/2026	
JC00149069	RCD POWER BOARD	HPM 30MA			20/01/2026	20/01/2027	20/01/2026	
JC00149070	RCD POWER BOARD	HPM 30MA			20/01/2026	20/01/2027	20/01/2026	
JC00149071	RCD POWER BOARD	TESLA 30MA			20/01/2026	20/01/2027	20/01/2026	
JC00149072	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149073	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149074	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149075	COFFEE GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149076	RCD POWER BOARD	ARLEC 30MAA			20/01/2026	20/01/2027	20/01/2026	
JC00149077	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149078	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149079	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149080	COFFEE GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149081	RCD POWER BOARD	HPM 30MA			20/01/2026	20/01/2027	20/01/2026	
JC00149082	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149083	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149084	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149085	COFFEE GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149086	RCD POWER BOARD	ARLEC 30MAA			20/01/2026	20/01/2027	20/01/2026	
JC00149087	EXTN LEAD	FAIL OPEN CONNECTION			20/01/2026	20/01/2027	20/01/2026	
JC00149088	COFFEE GRINDER				20/01/2026	20/01/2027	20/01/2026	



Asset ID	Description	Make	Model	Serial No	Last Test	Next Test	Last Visual	Next Visual
JC00149089	RCD POWER BOARD	ARLEC 30MA			20/01/2026	20/01/2027	20/01/2026	
JC00149090	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149091	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149092	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149093	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149094	GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149095	GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149096	GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149097	GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149098	GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149099	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149100	FRIDGE				20/01/2026	20/01/2027	20/01/2026	
JC00149101	FRIDGE				20/01/2026	20/01/2027	20/01/2026	
JC00149102	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149103	COFFEE MACHINE				20/01/2026	20/01/2027	20/01/2026	
JC00149104	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149105	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149106	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149107	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149108	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149109	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149110	EXTN LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149111	POWER BOARD				20/01/2026	20/01/2027	20/01/2026	
JC00149112	GRINDER				20/01/2026	20/01/2027	20/01/2026	
JC00149113	RCD POWER BOARD				20/01/2026	20/01/2027	20/01/2026	
JC00149114	RCD POWER BOARD				20/01/2026	20/01/2027	20/01/2026	
JC00149116	PWR CORD SCLAES				20/01/2026	20/01/2027	20/01/2026	
JC00149117	HEAT SEALER				20/01/2026	20/01/2027	20/01/2026	
JC00149118	SCALES				20/01/2026	20/01/2027	20/01/2026	
JC00149119	FIG8 LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149120	AC ADAPTOR				20/01/2026	20/01/2027	20/01/2026	
JC00149121	IEC LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149122	AC ADAPTOR				20/01/2026	20/01/2027	20/01/2026	
JC00149123	FIG8 LEAD				20/01/2026	20/01/2027	20/01/2026	
JC00149124	AC ADAPTOR				20/01/2026	20/01/2027	20/01/2026	

Total Assets: 74

Detailed Latest Test Results

COFFEE ON CUE
19 Hall St
YARRAVILLE 3013



Client: COFFEE ON CUE 1/26

Site: COFFEE ON CUE

Location: JAN 2026

Asset ID: JC00149050	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.42	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass

Overall: Pass

Asset ID: JC00149051	Description: MILK FRIDGE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.38	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: JC00149052	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.22	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass

Overall: Pass

Asset ID: JC00149053	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.24	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information

Overall: Pass



Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Overall: Pass				

Asset ID: JC00149054	Description: MILK FRIDGE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.59	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149055	Description: MILK FRIDGE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.39	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149056	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.31	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Overall: Pass				

Asset ID: JC00149057	Description: MILK FRIDGE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.38	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Overall: Pass				



Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149058	Description: MILK FRIDGE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.5	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149059	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.19	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149060	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.18	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149061	Description: COFFEE GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.36	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				



Asset ID: JC00149062	Description: COFFEE GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.19	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149063	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.28	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149064	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.19	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149065	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.18	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149066	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	------------------------	--------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.32	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass

Overall: Pass

Asset ID: JC00149067	Description: COFFEE GRINDER		User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.62	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Overall: Pass

Asset ID: JC00149068	Description: RCD POWER BOARD		User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	43	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	33	ms	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	250.8	V	Information
Load Current	20/01/2026	0.077	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
				Overall: Pass

Overall: Pass

Asset ID: JC00149069	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
----------------------	------------------------------	--------------	---



Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	43	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	33	ms	Pass
IEC Lead Continuity	20/01/2026	0.13	ohm	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	245.3	V	Information
Load Current	20/01/2026	0.071	A	Information
PE Conductor Current	20/01/2026	0.04	mA	Pass
Overall: Pass				

Asset ID: JC00149070	Description: RCD POWER BOARD		User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	43	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	38	ms	Pass
IEC Lead Continuity	20/01/2026	0.13	ohm	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	248.4	V	Information
				Overall: Pass



Load Current	20/01/2026	0.055	A	Information
PE Conductor Current	20/01/2026	0.04	mA	Pass
				Overall: Pass

Asset ID: JC00149071	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	24	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	34	ms	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	249.1	V	Information
Load Current	20/01/2026	0.063	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
				Overall: Pass

Asset ID: JC00149072	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.33	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149073	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
				Overall: Pass



Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.63	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149074	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.06	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149075	Description: COFFEE GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.28	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149076	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	9	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	19	ms	Pass
IEC Lead Continuity	20/01/2026	0.18	ohm	Pass
IEC Lead Continuity	20/01/2026	0.16	ohm	Pass
Overall: Pass				



Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	247.4	V	Information
Load Current	20/01/2026	0.055	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
				Overall: Pass

Asset ID: JC00149077	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.31	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149078	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.14	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149079	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.12	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149080	Description: COFFEE GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
				Overall: Pass



Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.12	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149081	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	32	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	33	ms	Pass
IEC Lead Continuity	20/01/2026	0.18	ohm	Pass
IEC Lead Continuity	20/01/2026	0.17	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	248.3	V	Information
Load Current	20/01/2026	0.068	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
				Overall: Pass

Asset ID: JC00149082	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.17	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass



Asset ID: JC00149083	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.26	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149084	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.67	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149085	Description: COFFEE GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.79	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149086	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	19	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
Overall: Pass				



RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	29	ms	Pass
IEC Lead Continuity	20/01/2026	0.16	ohm	Pass
IEC Lead Continuity	20/01/2026	0.15	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	249.8	V	Information
Load Current	20/01/2026	0.06	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
				Overall: Pass

Asset ID: JC00149087	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.42	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026	Live / Neutral Open		Fail
				Overall: Fail

Asset ID: JC00149088	Description: COFFEE GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.13	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149089	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
				Overall: Pass



RCD Trip Time (Portable)	20/01/2026	19	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	29	ms	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
IEC Lead Continuity	20/01/2026	0.14	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	250	V	Information
Load Current	20/01/2026	0.06	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
Overall: Pass				

Asset ID: JC00149090	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.41	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Overall: Pass				

Asset ID: JC00149091	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.24	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Overall: Pass				

Asset ID: JC00149092	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Overall: Pass				



IEC Lead Continuity	20/01/2026	0.47	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Overall: Pass				

Asset ID: JC00149093	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.12	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149094	Description: GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.1	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149095	Description: GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.09	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149096	Description: GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.1	ohm	Pass
Overall: Pass				



Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149097	Description: GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.16	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149098	Description: GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.1	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149099	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.1	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Overall: Pass				

Asset ID: JC00149100	Description: FRIDGE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.32	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Overall: Pass				



Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149101	Description: FRIDGE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.09	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149102	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.61	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149103	Description: COFFEE MACHINE	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.09	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00149104	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.2	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Overall: Pass				



Asset ID: JC00149105	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.23	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149106	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.3	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149107	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.36	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149108	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.58	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass



Asset ID: JC00149109	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.23	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149110	Description: EXTN LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.59	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149111	Description: POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.59	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149112	Description: GRINDER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.1	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149113	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	------------------------------	--------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	30	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	33	ms	Pass
IEC Lead Continuity	20/01/2026	0.15	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	246	V	Information
Load Current	20/01/2026	0.063	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
Overall: Pass				

Asset ID: JC00149114	Description: RCD POWER BOARD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	0	degrees	Information
RCD Trip Time (Portable)	20/01/2026	28	ms	Pass
RCD Trip Time Current (Portable)	20/01/2026	30	mA	Information
RCD Trip Time Angle (Portable)	20/01/2026	180	degrees	Information
RCD Trip Time (Portable)	20/01/2026	18	ms	Pass
IEC Lead Continuity	20/01/2026	0.18	ohm	Pass
IEC Lead Continuity	20/01/2026	0.18	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
IEC Lead Polarity	20/01/2026			Pass
Live Voltage	20/01/2026	254.2	V	Information
Load Current	20/01/2026	0.063	A	Information
PE Conductor Current	20/01/2026	0.03	mA	Pass
Overall: Pass				



Asset ID: JC00149116	Description: PWR CORD SCLAES	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.16	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass
				Overall: Pass

Asset ID: JC00149117	Description: HEAT SEALER	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Earth Continuity	20/01/2026	0.16	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149118	Description: SCALES	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149119	Description: FIG8 LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00149120	Description: AC ADAPTOR	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519	
				Overall: Pass



Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: JC00149121	Description: IEC LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
----------------------	-----------------------	--------------	---

Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
IEC Lead Continuity	20/01/2026	0.1	ohm	Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
IEC Lead Polarity	20/01/2026			Pass

Overall: Pass

Asset ID: JC00149122	Description: AC ADAPTOR	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
----------------------	-------------------------	--------------	---

Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: JC00149123	Description: FIG8 LEAD	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
----------------------	------------------------	--------------	---

Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass
Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: JC00149124	Description: AC ADAPTOR	User: TT2134	Test Instrument: Seaward PrimeTest Elite 23F-0519
----------------------	-------------------------	--------------	---

Test Type	Date	Result	Unit	Status
Plugs	20/01/2026			Pass
Flexible cord	20/01/2026			Pass
Cover / Guards	20/01/2026			Pass

Overall: Pass



Insulation Voltage	20/01/2026	500	V	Information
Insulation	20/01/2026	> 19.99	MOhm	Pass
				Overall: Pass

Total Tests: 74